

Field_ID	Flushed_Y/N	Laboratory_Sample_ID	Laboratory_Name	Lab_Certification_ID	Date_Sampled	Time_Sample_d	Analytical_Method	Date_of_Analysis	Time_of_Analysis	Concentration_in_ug/L	Reporting_Limit_ug/L	Dilution_Factor	Digested_Y/N	Qualifier
Field Blank	N	2244731001	ALS	NJ PA010	7/7/2017	9:40	EPA 200.8	7/12/2017	15:41	< 2.0	2	1	Y	ND
DTS-1-Cafeteria-FP-P	N	2244731002	ALS	NJ PA010	7/7/2017	9:41	EPA 200.8	7/12/2017	15:43	5.8	2	1	Y	
DTS-1-Cafeteria-WC-P	N	2244731003	ALS	NJ PA010	7/7/2017	9:41	EPA 200.8	7/12/2017	15:52	< 2.0	2	1	Y	ND
DTS-1-Room 3- CF-P	N	2244731004	ALS	NJ PA010	7/7/2017	9:44	EPA 200.8	7/12/2017	15:54	4.1	2	1	Y	
DTS-2-Rear Hall-WC-P	N	2244731005	ALS	NJ PA010	7/7/2017	9:45	EPA 200.8	7/12/2017	15:57	4.8	2	1	Y	
DTS-2-Front Hall-WC-P	N	2244731006	ALS	NJ PA010	7/7/2017	9:48	EPA 200.8	7/12/2017	16:05	< 2.0	2	1	Y	ND
DTS-2-MO-TF-P	N	2244731007	ALS	NJ PA010	7/7/2017	9:49	EPA 200.8	7/12/2017	16:08	2.1	2	1	Y	

Exceeds EPA Action Limit (> 15ppb)

Bldg ID - Floor - Room / Location ID - Outlet Type - Number in Sequence - Primary

OUTLET TYPE

BF = Bathroom Faucet

CF = Classroom Faucet

DW = Drinking Water Fountain

FP = Food Prep

HS = Hand Sink

IM = Ice Machine

KC = Kitchen Outlet, Cold

KT= Kettle

SB = Sink/Bubbler Combination

TF = Teachers Faucet

WC = Water Cooler

BT = Bottle Filler