

Field_ID	Flushed Y/N	Laboratory Sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit ug/L	Dilution Factor	Digested Y/N	Qualifier
RDS-FIELD BLANK	N	2241672001	ALS	NJ PA010	6/23/2017	9:28	EPA 200.8	7/1/2017	11:47	< 2.0	2	1	Y	ND
RDS-1-MEDIA-TF-P	N	2241672002	ALS	NJ PA010	6/23/2017	9:29	EPA 200.8	7/1/2017	11:50	2.5	2	1	Y	
RDS-1-NURSE-NS-P	N	2241672003	ALS	NJ PA010	6/23/2017	9:30	EPA 200.8	7/1/2017	11:53	4.5	2	1	Y	
RDS-1-EXAMRM-NS-P	N	2241672004	ALS	NJ PA010	6/23/2017	9:31	EPA 200.8	7/1/2017	11:55	< 2.0	2	1	Y	ND
RDS-1-10-DW-P	N	2241672005	ALS	NJ PA010	6/23/2017	9:31	EPA 200.8	7/1/2017	12:03	9.7	2	1	Y	
RDS-1-9-10KIT-TF-P	N	2241672006	ALS	NJ PA010	6/23/2017	9:33	EPA 200.8	7/1/2017	12:06	< 2.0	2	1	Y	ND
RDS-1-9-DW-P	N	2241672007	ALS	NJ PA010	6/23/2017	9:35	EPA 200.8	7/1/2017	12:09	17.1	2	1	Y	
RDS-1-COMMONS-DW-P	N	2241672008	ALS	NJ PA010	6/23/2017	9:39	EPA 200.8	7/1/2017	12:17	< 2.0	2	1	Y	ND
RDS-1-8-DW-P	N	2241672009	ALS	NJ PA010	6/23/2017	9:40	EPA 200.8	7/1/2017	12:19	38	2	1	Y	
RDS-1-7-8KIT-TF-P	N	2241672010	ALS	NJ PA010	6/23/2017	9:41	EPA 200.8	7/1/2017	12:22	< 2.0	2	1	Y	ND
RDS-1-LIVING CENTER-TF-P	N	2241672011	ALS	NJ PA010	6/23/2017	9:43	EPA 200.8	7/1/2017	12:25	< 2.0	2	1	Y	ND
RDS-1-OT-PT-CF-P	N	2241672012	ALS	NJ PA010	6/23/2017	9:45	EPA 200.8	7/1/2017	12:28	6.2	2	1	Y	
RDS-1-6-DW-P	N	2241672013	ALS	NJ PA010	6/23/2017	9:48	EPA 200.8	7/1/2017	12:36	9.8	2	1	Y	
RDS-1-5-6KIT-TF-P	N	2241672014	ALS	NJ PA010	6/23/2017	9:50	EPA 200.8	7/1/2017	12:38	< 2.0	2	1	Y	ND
RDS-1-5-DW-P	N	2241672015	ALS	NJ PA010	6/23/2017	9:51	EPA 200.8	7/1/2017	12:41	< 2.0	2	1	Y	ND
RDS-1-4-DW-P	N	2241672016	ALS	NJ PA010	6/23/2017	9:53	EPA 200.8	7/1/2017	12:44	12.6	2	1	Y	
RDS-1-4-3KIT-TF-P	N	2241672017	ALS	NJ PA010	6/23/2017	9:54	EPA 200.8	7/1/2017	12:46	< 2.0	2	1	Y	ND
RDS-1-3-DW-P	N	2241672018	ALS	NJ PA010	6/23/2017	9:55	EPA 200.8	7/1/2017	12:54	28.7	2	1	Y	
RDS-1-2-DW-P	N	2241672019	ALS	NJ PA010	6/23/2017	9:57	EPA 200.8	7/1/2017	12:57	< 2.0	2	1	Y	ND
RDS-1-1-2KIT-TF-P	N	2241672020	ALS	NJ PA010	6/23/2017	9:59	EPA 200.8	7/1/2017	13:00	< 2.0	2	1	Y	ND
RDS-1-1-DW-P	N	2241672021	ALS	NJ PA010	6/23/2017	10:00	EPA 200.8	7/1/2017	13:29	54.6	2	1	Y	
RDS-1-KIT-IM-P	N	2241672022	ALS	NJ PA010	6/23/2017	10:01	EPA 200.8	#####	10:52	< 1.0	1	1	Y	ND
RDS-1-KIT-SP-P	N	2241672023	ALS	NJ PA010	6/23/2017	10:02	EPA 200.8	7/1/2017	13:32	4.4	2	1	Y	
RDS-1-KIT-FP1-P	N	2241672024	ALS	NJ PA010	6/23/2017	10:03	EPA 200.8	7/1/2017	13:35	< 2.0	2	1	Y	ND
RDS-1-KIT-FP2-P	N	2241672025	ALS	NJ PA010	6/23/2017	10:04	EPA 200.8	7/1/2017	13:37	5.5	2	1	Y	

Exceeds EPA Action Limit (> 15ppb)

Bldg ID - Floor - Room / Location ID - Outlet Type - Number in Sequence - Primary

OUTLET TYPE

- BF = Bathroom Faucet
- CF = Classroom Faucet
- DW = Drinking Water Fountain
- FP = Food Prep
- HS = Hand Sink
- IM = Ice Machine
- KC = Kitchen Outlet, Cold
- KT= Kettle
- SB = Sink/Bubbler Combination
- TF = Teachers Faucet
- WC = Water Cooler